

# Annexure C

Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SN-11 September 2023

Dated: 13/09/23

It is certified that an inspection team headed by P. H.E. DIVISION, MADHUBANI

(Name of Officers with designation) from RAMAN KUMAR JHA - CHEMIST

(Name of Department/ Office) inspected the DRINKING WATER AND SANITARY CONDITION  
P. H.E. DIVISION, MADHUBANI

(Name & Address of the school) on 13/09/23 (date of inspection), checked the water test report  
S.S. GYAN BHARTI, AMBEDKAR CHOWK, BEHTA, BENIPATTI

submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 12/09/2024  
(one year)

Signature with Seal: [Signature] CHEMIST  
P.H.E.D. Madhubani

Name : RAMAN KUMAR JHA

Designation : Lab. Asst.

Assistant Engineer of  
the Govt. Public Health Department (PHED)/  
Authorised officer of the Local Body ✓

Name & Address of the Office / Department : .....

P. H.E. DIVISION,  
MADHUBANI

To Dr. Reeta Jha

S.S. Gyan Bharti, Ambedkar

Chowk, Behta, Benipatti (Madhubani).

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

# DISTRICT LEVEL WATER TESTING LABORATORY P.H.DIVISION, MADHUBANI

Sampling Date:- 12/09/2023  
Testing Date:- 13/09/2023  
Months:- September 2023

SI No.	Block	Panchayat	Village	Habitation	Name of Location/Nearest Person	PH.	Tub.	T.H	T.A	Ca	Mg	Cl	Fe	F	SO4	NO3	TDS	EC	AS	MPNI	Remarks
1	Benipatti	Behta	Behta	Ambedkar Chowk	S.S Gyan Bharti	7.1	2	152	195	38	27.36	17	0.24	0.53	NT	8	207	313	NT	A	
Min-Max-Permissible Limit						6.5 - 8.5	1.0-05	200 - 600	200 - 600	75 - 200	30 - 100	250 - 1000	1.0	0.5 - 1.5	200 - 400	45	500 - 2000		0.01- NR		

\*A - Absent  
\*NT - Not Tested

  
 12.09.2023  
 Chemist/Lab. Assistant  
 District Laboratory, Madhubani

