

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 12 May 2026 / P.H.C.

Dated: 12/05/2026

It is certified that an inspection team headed by Dr. P. N. Jha

I/c Medical Officer, from P.H.C. Benipatti (Name of Officers with designation)

from P.H.C. Benipatti (Madhubani) PHED/P.H.C.

inspected the S.S. GYAN BHARTI, Ambedkar Chowk, Behta, Bpt (Madhubani)

(Name & Address of the school) on 12.05.2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. LAB/MDB/MAY/58

dated 13/05/2026 of (PHED Lab)

certified that the

S.S. GYAN BHARTI (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till Three years

Juship
14/5/26

Signature with Seal:

Name

Dr. Praetab Narayan Jha

Designation

MOIC

Name & Address of the Office / Department

I/c MEDICAL OFFICER Health
P.H.C. Benipatti
(Madhubani)

To

Dr. Reeta Jha

Principal, S.S. Gyan Bharti, Benipatti

(Name & Address of the Institution) (Madhubani)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**DISTRICT LEVEL WATER TESTING LABORATORY
P.H.DIVISION, MADHUBANI**

Sampling Date:- 12/05/2026
Testing Date:- 13/05/2026
Months:- MAY 2026.

Sample Collected & Submitted by LAB-STAFF.

Sl No.	Block	Panchayat	Village	Source of Water	Name of Location/Nearest Person	PH.	Tub.	T.H	T.A	Ca	Mg	Cl	Fe	F	SO4	NO3	TDS	EC	AS	Remarks
1	BENIPTTI	BEHTA	BEHTA	BORING	S.S GYAN BHARTI AMBEDKAR CHOWK	7.4	2.2	168	265	36	12	20	0.32	0.12	00	0.5	270	368	NT	
Min-Max-Permissible Limit																				
						6.5 - 8.5	1.0-05	200 - 600	200 - 600	75 - 200	30 - 100	250 - 1000	1.0	1 - 1.5	200 - 400	45	500 - 2000		0.01 - NR	

*NT - Not Tested
*BDL - Below Detection Limit

Sauvabh
13/05/26

Natishin
Chemist
District Laboratory, Madhubani